



MAY 25, 2022

**LAGUNA TREATMENT PLANT EMERGENCY GENERATOR FUEL TANK AND FLEET FUELING STATION REPLACEMENT  
CONTRACT NO. C02192**

**ADDENDUM NO. 1**

**SPECIFICATIONS:**

1. Page 1, NOTICE TO BIDDERS, second subparagraph shall be replaced in its entirety:

**Bid Acceptance Deadline**

Sealed bids will be accepted at the Transportation and Public Works Department, 69 Stony Circle, Santa Rosa, California 95401 until 2:00 p.m., June 7, 2022, for Laguna Treatment Plant Emergency Generator Fuel Tank and Fleet Fueling Station Replacement, Contract No. C02192. (Engineer's Estimate: \$981,483).

2. Page 1, NOTICE TO BIDDERS, second subparagraph shall be replaced in its entirety:

**Bid Opening Teleconference Call**

Prospective bidders, subcontractors, and materials suppliers are invited to attend the Bid opening teleconference call scheduled to be held at 2:00 p.m., June 7, 2022. The teleconference can be accessed by dialing 1 (707) 543-4700, participant code 949-5581#.

3. Page 3, NOTICE TO BIDDERS, ESTIMATED QUANTITIES shall be replaced in its entirety with the attached page 3R.
4. Page 15, Section 5, CONTROL OF WORK, 5-1.05 ORDER OF WORK, the following shall be added in its entirety as the second paragraph:

Attention is directed to Section 15-7 Utility Clearances and Section 01 31 13, Project Coordination, 1.03, E.

5. Page 45, Section 15, EXISTING FACILITIES, 15-7 Utility Clearances, the following shall be added in its entirety as the forth paragraph:

Contractor shall supply two additional potholes specific existing 2-inch diesel fuel line between the existing diesel pump station and existing underground fuel tank, field located at the Engineers direction.

6. Page 66, Section 01 11 00, SUMMARY OF WORK, 1.01 DESCRIPTION OF BID ITEMS, subparagraph B.4 shall be replaced in its entirety with the following:

**Bid Item 4 - Groundwater Management Allowance:** This bid item shall be paid for on a **lump sum** basis to provide management efforts as it relates to encountered groundwater during the Project as specified in Section 02 65 00, Underground Storage Tank Removal and Section 31 23 19.01, Dewatering. This bid item includes all labor, materials, and equipment necessary to preparation of the groundwater management associated with the Special Provisions and the City's standards. The estimated cost designated by the City is noted in Bid Schedule. Payment will be in accordance with Standard Specifications Section 9-1.04 Force Account or based on an agreed price. Standard Specifications Section 9-1.068 and 9-1.06C shall not be considered as part of this bid item.

7. Page 111, Section 02 65 00, UNDERGROUND STORAGE TANK REMOVAL, 3.05 EXCAVATED SOIL STOCKPILES, subparagraph B.2 shall be replaced in its entirety with the following:

Contractor will be responsible for testing soil for potential volatile or semi-volatile organic compounds as outlined in Appendix A of this Section, Underground Storage Tanks (UST) Removal Procedures.

8. Page 112, Section 02 65 00, UNDERGROUND STORAGE TANK REMOVAL, 3.05 EXCAVATED SOIL STOCKPILES, subparagraph B3 shall be replaced in its entirety with the following:

Full compensation for testing, stockpiling, and maintaining excavated soils shall be considered as included in the prices paid for Underground Storage Tank Removal, and no additional compensation will be allowed therefor.

9. Page 118, Section 02 65 00, UNDERGROUND STORAGE TANK REMOVAL – APPENDIX A – UNDERGROUND STORAGE TANK REMOVAL PROCEDURE, section C title shall be replaced in its entirety with the following:

Soil and Groundwater Sampling

10. Page 217, Section 31 23 19.01, DEWATERING, 3.03 GROUNDWATER CONTROL, subparagraph A.2 shall be replaced in its entirety with the following:

Contractor will be responsible for testing groundwater in accordance with Section 02 65 00, Underground Storage Tank Removal. Contractor will test for potential volatile or semi-volatile organic compounds as outlined in Appendix A of Section 02 65 00 Underground Storage Tank Removal. Contractor responsible for storing encountered groundwater until further direction provided by the City. Full compensation for testing shall be considered as included in the prices paid for under Groundwater Management Allowance.

11. Page 217, Section 31 23 19.01, DEWATERING, 3.03 GROUNDWATER CONTROL, subparagraph A.3 shall be replaced in its entirety with the following:

Groundwater Management Allowance shall be paid for at the contract lump sum price, which price shall include full compensation for furnishing all labor, materials, tools and equipment, and doing all the work involved in groundwater management, including but not limited to one 12,600-gallon storage tank for one month's duration, and disposing of

groundwater on Work Site. For bidding purposes, Contractor to assume disposal site is approximately 300 feet from storage tank location. The estimated cost designated by the City is noted in the Bid Schedule. Payment will be in accordance with Standard Specifications Section 9-1.04 Force Account or based on an agreed price. Standards Specifications Section 9-1.068 and 9-1.06C shall not be considered as part of this bid item.

12. Page 218, Section 31 23 19.01, DEWATERING, 3.03 GROUNDWATER CONTROL, subparagraph B.3 shall be replaced in its entirety with the following:

Full compensation for collecting, conveying, and disposal of contaminated groundwater shall be considered paid for under Groundwater Management Allowance.

13. Page 218, Section 31 23 19.01, DEWATERING, 3.03 GROUNDWATER CONTROL, subparagraph C.2 shall be replaced in its entirety with the following:

Full compensation for collecting, conveying, and disposal of noncontaminated groundwater shall be considered as included in the prices paid for under Groundwater Management Allowance.

14. Page 261, UNIT PRICE SCHEDULE, shall be replaced in its entirety with the attached page 261R.

**PLANS:**

1. Sheet 10, GENERAL SITE NOTES, the following shall be added in its entirety:

8. Access road adjacent to the blower electrical building will not be accessible due to temporary existing Plant facility.

2. Sheet 11, NOTES, the following shall be added in its entirety:

5. For bidding purposes, contractor shall assume new 2" DFS shown on plans shall be revised between Point 219 to 220, approximately five feet east of existing 2-inch diesel fuel line utility trench.



---

TRACY DUENAS, P.E.  
Supervising Engineer

**CITY OF SANTA ROSA  
C02192 - LAGUNA TREATMENT PLANT EMERGENCY GENERATOR FUEL TANK  
AND FLEET FUELING STATION REPLACEMENT  
ESTIMATED QUANTITIES**

<b>Item No.</b>	<b>Description</b>	<b>Quantity</b>	<b>Units</b>
1	UTILITY CLEARANCES	1	LS
2	HOT ASPHALT MIX	210	TON
3	DEMOLITION	1	LS
4	GROUNDWATER MANAGEMENT ALLOWANCE	1	LS
5	UNDERGROUND STORAGE TANK REMOVAL	1	LS
6	CONTAMINATED GROUNDWATER AND SOIL MANAGEMENT ALLOWANCE	1	LS
7	FUEL STORAGE TANKS AND DISPENSING EQUIPMENT	1	LS
8	ELECTRICAL AND INSTRUMENTATION INSTALLATION	1	LS
9	PIPELINE AND GEAR PUMP INSTALLATION	1	LS

**CITY OF SANTA ROSA  
C02192 - LAGUNA TREATMENT PLANT EMERGENCY GENERATOR FUEL TANK AND FLEET FUELING STATION REPLACEMENT  
UNIT PRICE SCHEDULE**

**Bidder Name:** \_\_\_\_\_

Item No.	Description	Quantity	Units	Unit Price	Total Price
1	UTILITY CLEARANCES	1	LS	\$ _____	\$ _____
2	HOT ASPHALT MIX	210	TON	\$ _____	\$ _____
3	DEMOLITION	1	LS	\$ _____	\$ _____
4	GROUNDWATER MANAGEMENT ALLOWANCE	1	LS	\$ 30,000.00	\$ 30,000.00
5	UNDERGROUND STORAGE TANK REMOVAL	1	LS	\$ _____	\$ _____
6	CONTAMINATED GROUNDWATER AND SOIL MANAGEMENT ALLOWANCE	1	LS	\$ 40,000.00	\$ 40,000.00
7	FUEL STORAGE TANKS AND DISPENSING EQUIPMENT	1	LS	\$ _____	\$ _____
8	ELECTRICAL AND INSTRUMENTATION INSTALLATION	1	LS	\$ _____	\$ _____
9	PIPELINE AND GEAR PUMP INSTALLATION	1	LS	\$ _____	\$ _____
<b>GRAND TOTAL BID</b>					<b>\$ _____</b>